

# Certificate of Test

*We hereby declare that the item described below  
has been tested by BSI and  
complies with the requirements of*

*BS EN 60529: 1992 Specification for Degrees of protection by enclosures (IP Code). For  
a Classification of IP68 Category 1, protection against ingress of solid foreign objects  
(dust tight) and protection against ingress of water (continuous immersion)*

*The full details of the tests and the results are given in  
our Report No: 288/4064881 Dated: 25 November 1999*

*Description of item tested:* Cable joint enclosures  
Type BS3/2+CS3/2/C  
Type BS1/2+CS4/C

*Submitted by:* PTC  
Mill Chase Barn Wildings Lane  
Steeple Bumpstead Haverhill  
Suffolk CB9 7EQ

*Certificate authorised by:*

R. J. Wells

*Title*

*Laboratory Manager*

*Date*

*25 November 1999*



TESTING  
No. 0135

*Attention is drawn to the conditions upon which this  
declaration is issued, namely:*

*1. The general and specific conditions of the BSI Product  
Services, Test Leaflet 1 apply in all respects. Copies of  
this leaflet are available on request.*

*2. This Declaration applied only to the particular sample  
tested and to the specific tests carried out as detailed in  
the Report referred to above.*

*3. This declaration does not indicate any measure of  
Approval, Certification, Supervision, Control or  
Surveillance by BSI to this or any related product.*

BSI Product Services, Maylands Avenue, Hemel Hempstead, Hertfordshire HP2 4SQ